Cethana Power Station

Mersey-Forth Catchment

Cethana Power Station is the fifth station in the Mersey-Forth scheme. The station was commissioned in 1971 and houses a single Fuji francis turbine coupled to a Fuji generator.

Cethana Power Station is a single-machine underground station and is supplied with water from Lake Cethana which is fed by the outflow from Lemonthyme (Mersey River) and Wilmot (Lake Gairdner) Power Stations and uncontrolled flow from the Forth River. Water from the station is returned to the Forth River through a tailrace tunnel which has a tailrace gate structure at the outlet portal.

The turbine has a partially embedded spiral casing and is connected to a 130 metre-long steel lined power tunnel with a vertical lift, gravity closed intake gate designed to cut off full flow. No relief valve or turbine inlet valve is installed in the power station.

TOYOTA

Twin bulkhead gates at the tailrace gate structure permit dewatering of the tailrace and draft tube.

The station output is fed to the outdoor switchyard via three single-phase $13.8\,\text{kV}/220\,\text{kV}$ generator transformers and associated $220\,\text{kV}$ oil filled cables. There is also a spare single-phase transformer and associated cable for contingency. The transformers are situated underground, adjacent to the generator.

Scheme:		Mersey Forth	
Year commissioned:		1971	
Power station structure:		Underground, 37 m long x 18 m wide x 25 m high excavation, housing a generating set, 4 single-phase transformers and assembly bay with service block.	
Static head:		99 m	
Generating set:		Vertical shaft generating set comprising a 100 MW francis turbine directly coupled to a 3-phase, 50Hz, 100 MVA synchronous generator and with provisions for synchronous compensator operation.	
Turbine manufacturer:	Fuji	Generator manufacturer:	Fuji
Rated head:	98 m	Rated output:	100 MVA
Rated discharge:	113 m ^{3/s}	Power factor:	0.85
Rated speed:	200 rev/min	Rated voltage:	13.8 kV



